

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3230-0935:107 Page 1 of 1

CATEGORY: Leakage Dampers (Smoke)

LISTEE: Nailor Industries, 4714 Winfield, Houston TX 77039
Contact: John Young (281) 590-1172 FAX (281) 590-3086

DESIGN: Models *1210, *1260, *1280 and *1290S leakage rated dampers. These dampers are of the single and multi-blade type construction for vertical and/or horizontal installation. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:	Model	Leakage Class/Temperature°F
	1210	I-350
	1260	II-350
	1280	I-250/350
	1290S	I-350

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as Class I or II leakage rated dampers *for use with listee's separately listed damper actuators. Refer to listee's Installation Instruction Manual for details.

NOTE: Refer to CSFM Listing *Category 3225 for listed fire rated dampers.

*Rev. 05-10-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**